Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SR486

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HEISER, DONALD			Phone #
Mailing Address: 643 SPRING VIEW DR			
City: EAGLE RIVER	State: WI	Zip Code: 54521	
County: Vilas	Co. Permit #	Notification #	Completed: 10-09-2004

Well Constructor (Business Name): ARTHUR P SIMAC	Lic. #: 4084	Facility ID # (Public Wells)	
Address: EAGLE RIVER WI 54521-0961		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

3. Well serves 1 # of	Hicap Well ? No
Private,potable	Hicap Property ? No
Heat Exchange____# of drillholes	Hicap Potable ?

1. Well Location

Town of LINCOLN				Fire # (if avail.): 643
Street Address or Road Name and Number: SPRINGVIEW DR				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 45.8824 °N -89.2128 °W				Method Code: GCD013
SW NW or Govt Lot #	Section: 11	Township: 39 N	Range: 10 E	

2. Well Type Reconstruction — UV185 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole	Lower Open Bedrock
Rotary - Mud Circulation	
Rotary - Air	
Rotary - Air & Foam	
Drill-Through Casing Hammer	
Reverse Rotary	
Cable-tool Bit ____in. dia...	
Dual Rotary	
Temp. Outer Casing ____in. dia	

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	STEEL	Surface	32
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	STAINLESS 10 SLOT	28	32

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	32

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 12 ft. below surface

Pumping at 8 GP M for 10 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BS		10-18-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		4
			Septic or Holding, or POWTS Tank		35

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	06/24/2009	NEAT CEMENT GROUT 0-32 5.5 BAGS USED	NO WATER

Created On: 12-17-2004 Updated On: 06-30-2020 Review Status: