

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SR570		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner CANARD, GREGORY & AMY HENNINGS						Phone # (262)546-0626		1. Well Location				Fire # (if avail.)			
Mailing Address 21832 121ST ST						Town of SALEM						21832			
City BRISTOL						State WI		Zip Code 53104				Street Address or Road Name and Number 21832 121ST ST			
County Kenosha		Co. Permit #		Notification #		Completed 12-18-2004		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) THOMAS L SCHULTZ				Lic. # 6643		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5054 °N -88.0718 °W				Method Code GCD013	
Address 124 HILLSIDE DR TWIN LAKES WI 53181-9785				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 36 1 N 20 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? 2 INCH POINT DRY Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 9		From (ft.) Surface		To (ft.) 148		Upper Enlarged Drillhole Lower Open Bedrock Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - I -		TOPSOIL				Surface		2							
T - C -		BROWN CLAY				2		15							
G - C P		GRAY CLAY HARDPAN				15		54							
G - C -		GRAY CLAY				54		137							
G - C P		GRAY CLAY HARDPAN				137		142							
- - Y -		SAND & GRAVEL				142		148							
6. Casing, Liner, Screen															
Dia. (in.) 5		Material, Weight, Specification ID NEW PVC CERTAINTED 1120 SDR 21 PWD 2241				From (ft.) Surface		To (ft.) 143							
Dia. (in.) 5		Screen type, material & slot size ID JAYCO PVC CONTINUOUS WRAPPED SLOT				From (ft.) 143		To (ft.) 148							
7. Grout or Other Sealing Material Method PUMPED Kind of Sealing Material GROUT WELL DF From (ft.) Surface To (ft.) 143 # Sacks Cement 13 S															
9. Static Water Level 80 ft. below ground surface															
10. Pump Test Pumping level 120 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ?															
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller TS						Lic #		Date Signed 12-18-2004							
Drill Rig Operator CLB						Lic or Reg #		Date Signed 12-18-2004							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		30	Collector Sewer - San or Storm		57
Building Overhang		20	Sewer - Building Sanitary		35

Comment:

Created On: 01-26-2005

Updated On: 08-23-2019

Review Status: