Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SR570

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CANARD, GREGORY & AMY HENNINGS	Phone #: (262)546-0626
Mailing Address: 21832 121ST ST	
City: BRISTOL	State: WI — Zip Code: 53104
County: Kenosha	Co. Permit #: — Notification #: — Completed: 12-18-2004
Well Constructor (Business Name): THOMAS L SCHULTZ	Lic. #: 6643 — Facility ID # (Public Wells):
Address: 124 HILLSIDE DR, TWIN LAKES WI 53181-9785	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of SALEM	Fire # (if avail.): 21832
Street Address or Road Name and Number: 21832 121ST ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.5054 °N -88.0718 °W	Method Code: GCD013
SE NE or Govt Lot #:	Section: 36 — Township: 1 N — Range: 20 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: 2 INCH POINT DRY
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	148

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	2
T	-	C	-	BROWN CLAY	2	15
G	-	C	P	GRAY CLAY HARDPAN	15	54
G	-	C	-	GRAY CLAY	54	137
G	-	C	P	GRAY CLAY HARDPAN	137	142
-	-	Y	-	SAND & GRAVEL	142	148

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	ID NEW PVC CERTAINTEED 1120 SDR 21 PWD 2241	Surface	143
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ID JAYCO PVC CONTINUOUS WRAPPED SLOT	143	148

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	143	13 S

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 12 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TS		12-18-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CLB		12-18-2004

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		30	Collector Sewer - San or Storm		57
Building Overhang		20	Sewer - Building Sanitary		35

Comment:

Created On: 01-26-2005 Updated On: 08-23-2019 Review Status: