Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SR604

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZIRBEL	Phone #: 6204218
Mailing Address: 7223 368TH AVE	
City: WHEATLAND	State: WI Zip Code: 53105-
County: Kenosha	Co. Permit #:
Notification #: 20441032	Completed: 08-05-2005
Well Constructor (Business Name): THOMAS L SCHULTZ	Lic. #: 6643
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 124 HILLSIDE DR TWIN LAKES WI 53181-9785	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1	

1. Well Location

Town of WHEATLAND

Fire # (if avail.):

Street Address or Road Name and Number: 7223 368TH AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.5694 °N -88.2563 °W	GCD013

SE SW or Govt Lot #	Section	Township	Range
	4	1 N	19 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: POINT DRY

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	90

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	2
-	-	Y	-	SAND GRAVEL	2	37
-	-	G	P	GRAVEL HARDPAN	37	80
-	-	Y	-	SAND & GRAVEL	80	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NEW PVC CERTAINTEED 1120-SDR21 PED 2241 PVC	Surface	85
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ID 5 FT X 5 INCH JOHNSON CONTINOUS .10 SLOT WRAPPED	85	90

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	85	8 S

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS		08-07-2005
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		40	Clearwater Sump		40
Building Overhang		12	Sewer - Building Sanitary		45
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 10-17-2005 Updated On: 08-23-2019 Review Status: