

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SR912		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HENSEL, JASON						Phone # (920)904-2588		1. Well Location				Fire # (if avail.)			
Mailing Address W8379 PRIEPKE RD						Town of LAMARTINE						W8365			
City ELDORADO						State WI		Zip Code 54932-				Street Address or Road Name and Number PRIEPKE RD			
County Fond du Lac		Co. Permit #		Notification # 21145916		Completed 10-19-2005		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) BRIAN SCHMITZ				Lic. # 6651		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7904 °N -88.5765 °W				Method Code GCD013	
Address N9309 CTY W FOND DU LAC WI 54935				Well Plan Approval #				SE NW		Section 10		Township 15 N		Range 16 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		200		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - Y -				SAND & GRAVEL				Surface		46					
- - P -				HARDPAN				46		82					
- - L -				LIMESTONE				82		200					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		IPSCO 6.625 ASTM A53B 280 WALL PLAIN ENDS				Surface		82							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface				5 S							
9. Static Water Level															
34 ft. below ground surface															
10. Pump Test															
Pumping level 100 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?															
11. Well Is															
18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
BS				Lic #		Date Signed									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Building Overhang		31
			Septic or Holding, or POWTS Tank		135

Comment:

Created On: 12-02-2005

Updated On: 10-08-2019

Review Status: