

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SR913		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KAUER, LARRY						Phone # (920)766-5410		1. Well Location				Fire # (if avail.)					
Mailing Address W4958 HWY 10						Town of HARRISON						W4958					
City MENASHA						State WI		Zip Code 54952-				Street Address or Road Name and Number HWY 10					
County Calumet		Co. Permit #		Notification # 20806741		Completed 09-12-2005		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) BRIAN SCHMITZ				Lic. # 6651		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)							
Address N9309 CTY W FOND DU LAC WI 54935				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 12 20 N 18 E		2. Well Type Replacement				of previous unique well # constructed in					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5				Reason for replaced or reconstructed well ? WELL WENT DRY							
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled				Heat Exchange ___ # of drillholes					
Hicap Property ? No						Hicap Potable ?		4. Potential Contamination Sources - ON REVERSE SIDE				5. Drillhole Dimensions and Construction Method					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
6		Surface		440		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		IPSCO 6.625 ASTM A53B 280 WALL PLAIN ENDS				Surface		158		R - C -		RED CLAY		Surface		158	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- - L H		LIMESTONE W/SHALE VEINS		158		440	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)						160 ft. below ground surface				20 in. above grade							
10. Pump Test						Pumping level 200 ft. below surface				Developed ? Yes							
Pumping at 20 GP M for 2 Hrs.						Pumping Method ?				Disinfected ? Yes							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?				Capped ? Yes							
Method MOUNDED						Filled & Sealed Well(s) as needed?				Yes							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
GRANULAR BENTONITE		Surface		6 S		BS				09-17-2005		Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		56	Downspout/Yard Hydrant		11
Building Overhang		12	Septic or Holding, or POWTS Tank		46

Comment:

Created On: 10-07-2005

Updated On: 10-07-2005

Review Status: