

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SR914		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KURSCHEIDT, BARB						Phone # (920)849-4773		1. Well Location				Fire # (if avail.)			
Mailing Address W4125 STONE RD						Town of BROTHERTOWN						W4125			
City CHILTON						State WI		Zip Code 53014				Street Address or Road Name and Number STONE RD			
County Calumet		Co. Permit #		Notification # 20636970		Completed 08-30-2005		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) BRIAN SCHMITZ				Lic. # 6651		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.97888 °N -88.24336 °W				Method Code OTH001	
Address N9309 CTY W FOND DU LAC WI 54935				Well Plan Approval # Approval Date (mm-dd-yyyy)		or Govt Lot # 109		Section 17 N		Township 19 E		Range			
						2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NONCOMPLYING									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Hicap Well ? No Hicap Property ? No Hicap Potable ?				Construction Type Drilled					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
8		Surface		41		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? 13depth ft. (If NO explain on back side)				- - C S		SANDY CLAY		Surface 13	
6		41		163						- - P -		HARDPAN		13 18	
										- - L -		LIMESTONE		18 163	
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 53 ft. below ground surface					
6		IPSCO 6.625 ASTM A53B 280 WALL PLAIN ENDS				Surface		41		10. Pump Test Pumping level 100 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material Method BRADENHEAD															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
NEAT CEMENT				Surface		41		18 S							
13. Constructor / Supervisory Driller															
BS				Lic #		Date Signed		08-31-2005							
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		30
			Septic or Holding, or POWTS Tank		47

Comment:

Created On: 02-13-2006

Updated On: 08-25-2022

Review Status: