Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SR915

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BAEHLER, RICHARD	Phone #: (920)921-0955
Mailing Address: W8207 CO Y	
City: OAKFIELD	State: WI — Zip Code: 53065
County: Fond du Lac	Co. Permit #: — Notification #: 20466887 — Completed: 08-10-2005
Well Constructor (Business Name): BRIAN SCHMITZ	Lic. #: 6651 — Facility ID # (Public Wells):
Address: N9309 CTY W, FOND DU LAC WI 54935	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of LAMARTINE	Fire # (if avail.): W8207
Street Address or Road Name and Number: CO Y	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.7338 °N -88.5687 °W	Method Code: GCD013
SE SE or Govt Lot #	Section: 27 — Township: 15 N — Range: 16 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD WELL IN WAY OF NEW MO

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	63
6	63	123

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	RED CLAY	Surface	4
-	-	L	-	LIMESTONE	4	92
-	H	H	-	HARD SHALE	92	95
-	-	L	-	LIMESTONE	95	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO 6.625 ASTM A53B .280 WALL PLAIN ENDS	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

69 ft. below ground surface

10. Pump Test

Pumping level 90 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	63	18 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BS		08-14-2005
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52
Building Overhang		13
Shoreline/Pool		52
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 09-20-2005 Updated On: 10-08-2019 Review Status: