

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SR915		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BAEHLER, RICHARD						Phone # (920)921-0955		1. Well Location				Fire # (if avail.)									
Mailing Address W8207 CO Y						Town of LAMARTINE						W8207									
City OAKFIELD						State WI		Zip Code 53065				Street Address or Road Name and Number CO Y									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Fond du Lac		20466887		08-10-2005		Latitude / Longitude in Decimal Degree (DD) 43.7338 °N -88.5687 °W				Method Code GCD013											
Well Constructor (Business Name) BRIAN SCHMITZ				Lic. # 6651		Facility ID # (Public Wells)				SE SE Section Township Range or Govt Lot # 27 15 N 16 E		Well Plan Approval #		Approval Date (mm-dd-yyyy)							
Address N9309 CTY W FOND DU LAC WI 54935						Hicap Permanent Well #						Common Well #		Specific Capacity 1							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?						2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL IN WAY OF NEW MO Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock											
8.75		Surface		63		Rotary - Mud Circulation				No											
6		63		123		Yes Rotary - Air				No											
Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						8. Geology															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		IPSCO 6.625 ASTM A53B .280 WALL PLAIN ENDS				Surface		63		R - C -		RED CLAY		Surface		4					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- - L -		LIMESTONE		4		92					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- H H -		HARD SHALE		92		95					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- - L -		LIMESTONE		95		123					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		69 ft. below ground surface				18 in. above grade							
6		IPSCO 6.625 ASTM A53B .280 WALL PLAIN ENDS				Surface		63		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 90 ft. below surface				Disinfected ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 20 GP M for 2 Hrs.				Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?				Filled & Sealed Well(s) as needed? Yes							
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method PRESSURE TREMIE														Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
NEAT CEMENT				Surface		63		18 S		BS				08-14-2005		Drill Rig Operator					
NEAT CEMENT				Surface		63		18 S		Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52	Shoreline/Pool		52
Building Overhang		13	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 09-20-2005

Updated On: 10-08-2019

Review Status: