Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ST202

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BECKER			Phone #
Mailing Address: 29114 N LAKE DR			
City: WATERFORD	State: WI	Zip Code: 53185	
County: Racine	Co. Permit #:	Notification #: 21826547	Completed: 12-13-2005

1. Well Location

Town of WATERFORD

Fire # (if avail.)

Street Address or Road Name and Number: 29114 N LAKE DR

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
EMANUEL BURGARINO	512	

Latitude / Longitude in Decimal Degree (DD): 42.8297 °N -88.2153 °W

Method Code: GCD013

NW	NE	Section	Township	Range
or Govt Lot #		11	4 N	19 E

Address: HYDRO WELL DRILLING, HALES CORNERS WI 53130

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.6

Reason for replaced or reconstructed well ?: NEW HOME

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	G	-	GRAVEL	Surface	24
-	-	C	-	CLAY	24	51
-	-	L	-	LIMESTONE	51	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE NEW STEEL 18.97 # PER FT ASTM-A 53 GRADE B WHEATLAND	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 14 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface	51	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EB		12-27-2005
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EB		12-27-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		94

Type	Qualifier	Distance
Building Overhang		14
Septic or Holding, or POWTS Tank		85

Comment:

Created On: 07-11-2006 Updated On: 06-28-2019 Review Status: