Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ST410

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WESTENBERGER, TOM			Phone #
Mailing Address: 8191 TRADING POST TR			
City: WEST BEND	State: WI	Zip Code: 53090	
County: Washington	Co. Permit #:	Notification #: 21826734	Completed: 12-08-2005

Well Constructor (Business Name): D & D WELL DRILLING CORP	Lic. #: 119	Facility ID # (Public Wells):	
Address: 36110 THOMAS DR OCONOMOWOC WI 53066		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of FARMINGTON

Fire # (if avail.)

Street Address or Road Name and Number
8191 TRADING POST TRL

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

SE	NE	Section	Township	Range
or Govt Lot #		3	11 N	20 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	103

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Yes Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK 18.97 PE MFG IPSCO ASTM A53B	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS SCREEN #20 SLOT	100	103

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	S	C	S	SOFT SANDY CLAY-GRAY	Surface	70
G	-	Y	U	DIRTY SAND & GRAVEL-CLAY	70	94
G	-	Y	-	SAND & GRAVEL-GRAY	94	103

9. Static Water Level
2 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CJ		12-14-2005
Drill Rig Operator	Lic or Reg #	Date Signed
DJ		12-14-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Overhang		18
Clearwater Sump		24
Downspout/Yard Hydrant		18

Type	Qualifier	Distance
Foundation Drain to Clearwater		20
Wastewater Sump		40
Sewer - Building Sanitary		33
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 09-18-2006 Updated On: 10-04-2006 Review Status: