Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ST606

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BLOOMER, ED			Phone #
Mailing Address: 1420 MEDFORD			
City: MISHAWAKA	State: IN	Zip Code: 46544	
County: Oconto	Co. Permit #	Notification #	Completed: 12-06-2004

Well Constructor (Business Name): TIMOTHY WILLIAM HARNOIS	Lic. #: 6220	Facility ID # (Public Wells)	
Address: T&T WELL DRLG & PUMP SERV, LAKEWOOD WI 54138		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of RIVERVIEW

Fire # (if avail.)

Street Address or Road Name and Number: FRENCH LAKE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NW NW or Govt Lot #	Section: 18	Township: 32 N	Range: 16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	70
6	70	94

Upper Enlarged Drillhole: Yes
Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND-GRAVEL	Surface	5
-	-	Y	G	SAND-GRAVEL-BOULDERS	5	65
-	-	Y	-	SAND-GRAVEL	65	94

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 GR B WHEATLAND WELDED 18.97 PER FT	Surface	89
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS #12	89	94

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 76 ft. below surface
Pumping at 15 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	70	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH		03-03-2005
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Building Overhang		25
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 03-29-2005 Updated On: 04-07-2005 Review Status: