

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ST609		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MAASS, ALLEN						Phone # (262)534-2937		1. Well Location				Fire # (if avail.)			
Mailing Address 31504 RED OAK LN								Town of LONG LAKE				4196			
City WATERFORD						State WI		Zip Code 53185							
County Florence		Co. Permit #		Notification #		Completed 12-14-2004		Subdivision Name FAY LK ASSOCIATION				Lot # 66		Block #	
Well Constructor (Business Name) TIMOTHY WILLIAM HARNOIS				Lic. # 6220		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address T&T WELL DRLG & PUMP SERV LAKEWOOD WI 54138				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE Section Township Range or Govt Lot # 8 39 N 15 E							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock							
10		Surface		15											
6		15		63		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - X -		SAND-CLAY				Surface		25							
- - Y -		SAND-GRAVEL				25		63							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		ASTM A53 GR B WHEATLAND WELDED 18.97 PER FT				Surface		59							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		STAINLESS #12				59		63							
7. Grout or Other Sealing Material															
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement SAND GRAVEL Surface 15															
9. Static Water Level 30 ft. below ground surface															
10. Pump Test Pumping level 48 ft. below surface Pumping at 20 GP M for 4 Hrs. Pumping Method ?															
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
TH								12-16-2004							
Drill Rig Operator						Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment: NO SEPTIC/SEWER YET

Created On: 03-29-2005

Updated On: 02-14-2006

Review Status: