Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ST609

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAASS, ALLEN	Phone #: (262)534-2937
Mailing Address: 31504 RED OAK LN	
City: WATERFORD	State: WI — Zip Code: 53185
County: Florence	Co. Permit #: — Notification #: — Completed: 12-14-2004
Well Constructor (Business Name): TIMOTHY WILLIAM HARNOIS	Lic. #: 6220 — Facility ID # (Public Wells):
Address: T&T WELL DRLG & PUMP SERV LAKEWOOD WI 54138	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.1

1. Well Location

Town of LONG LAKE	Fire # (if avail.): 4196
Street Address or Road Name and Number: 4196 FAY LK ASSOCIATION RD	
Subdivision Name: FAY LK ASSOCIATION	Lot #: 66 — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
SE SE or Govt Lot #	Section: 8 — Township: 39 N — Range: 15 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
6	15	63

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	X	-	SAND-CLAY	Surface	25
-	-	Y	-	SAND-GRAVEL	25	63

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 GR B WHEATLAND WELDED 18.97 PER FT	Surface	59
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	STAINLESS #12	59	63

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 48 ft. below surface
Pumping at 20 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SAND GRAVEL	Surface	15	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TH		12-16-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment: NO SEPTIC/SEWER YET

Created On: 03-29-2005 Updated On: 02-14-2006 Review Status: