

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ST739		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner JIM PANDOW BLDRS Phone # (608)862-3624						1. Well Location				Fire # (if avail.)		
Mailing Address N4295 PANDOW DR						Town of DECATUR				N4096		
City BROADHEAD State WI Zip Code 53520-						Street Address or Road Name and Number BIKE TRL						
County Green		Co. Permit #		Notification # 19997377		Completed 07-05-2005		Subdivision Name		Lot # 85	Block #	
Well Constructor (Business Name) ALLEN E SMITH				Lic. # 6639	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.6552 °N -89.3974 °W			Method Code GCD013		
Address 1910 WYNDHAM LN ROCKTON IL 61072				Well Plan Approval #		SE	SW	Section 11	Township 2 N	Range 9 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #	11	2 N	9 E			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method						8. Geology						
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
10	Surface	62	Yes Rotary - Mud Circulation Yes			-	-	S	-	SAND	Surface	15
6	62	184	Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)			R	-	C	S	RED CLAY W/SAND	15	58
-	-	-	-			-	-	L	-	LIMESTONE	58	143
-	-	-	-			-	-	N	H	RED/GRAY SANDSTONE W/SHALE STREAKS	143	184
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is		
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	20 ft. below ground surface				12 in. above grade		
6	BLK T&C #19.45 ASTM A53 WELL CASING MAVERICK USA			Surface	62	10. Pump Test				Developed ? Yes		
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)	Pumping level 36 ft. below surface				Disinfected ? Yes		
-	-			-	-	Pumping at 20 GP M for 3 Hrs.				Capped ? Yes		
-	-			-	-	Pumping Method ?				-		
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?						
Method						Filled & Sealed Well(s) as needed? No						
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement		NONE ON PROPERTY						
BENT DRILLING MUD W/CUTTINGS		Surface	62	-		13. Constructor / Supervisory Driller						
-		-	-	-		Lic #		Date Signed		-		
-		-	-	-		AES		07-18-2005		-		
-		-	-	-		Drill Rig Operator		Lic or Reg #		Date Signed		
-		-	-	-		-		-		-		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		15
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 08-02-2005

Updated On: 01-21-2020

Review Status: