Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SU211

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GOTTSCHALK, DON & EILEEN			Phone #: (847)526-9292
Mailing Address: 27930 N CONVERSE			
City: ISLAND LAKE	State: IL	Zip Code: 60042	
County: Juneau	Co. Permit #:	Notification #:	Completed: 04-28-2005

Well Constructor (Business Name): TERRY L MARSHALL	Lic. #: 216	Facility ID # (Public Wells):	
Address: 3774 STATE RD 13 WISCONSIN DELLS WI 53965-8906		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 6.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of LYNDON			Fire # (if avail.): W1346
Street Address or Road Name and Number: W1346 BAY VIEW LN			
Subdivision Name: THOMAS BAY ACS	Lot #: 4	Block #:	

Latitude / Longitude in Decimal Degree (DD): 43.7 °N -89.84656 °W				Method Code: GPS006
NE or Govt Lot #	NE	Section: 13	Township: 14 N	Range: 5 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	41
6	41	125

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- No — Rotary - Air ..... — Yes
- Yes — Rotary - Air & Foam ..... — No
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 2depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	S	SANDY LOAM	Surface	2
-	-	N	-	SANDSTONE	2	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE STEEL PIPE ASTM A-53 GR B 18.97 LBS/FT WHEATLAND STEEL	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT & WATER	Surface	41	12 S

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 20 GP M for 72 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLM		04-29-2005
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JJ		04-29-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90
Building Drain - Sanitary	>	10
Building Overhang	>	10
Clearwater Sump	>	10
Foundation Drain to Clearwater	>	10
Privy		196
Sewer - Building Sanitary	>	10
Septic or Holding, or POWTS Tank		98

Comment:

Created On: 06-27-2005 Updated On: 02-15-2006 Review Status: