Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SU362

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FROST, MIKE	Phone #: (920)716-2070
Mailing Address: 3310 WHITETAIL RUN	
City: BRILLION	State: WI — Zip Code: 54110
County: Manitowoc	Co. Permit #: 21856 — Notification #: 21856340 — Completed: 01-03-2006
Well Constructor (Business Name): STEPHEN D KEIFENHEIM	Lic. #: 4225 — Facility ID # (Public Wells):
Address: KEIFENHEIM WELL DRLG & PUMP SERVICE, BRILLION WI 54110-9318	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.3

1. Well Location

Fire # (if avail.):

Town of ROCKLAND

Street Address or Road Name and Number: 3310 WHITETAIL RUN

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.1382 °N -88.0339 °W — Method Code: GCD013

NW or Govt Lot # — NE — Section: 7 — Township: 19 N — Range: 21 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: WELL FOR NEW HOUSE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	87

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	C	-	RED CLAY	Surface	73
-	-	P	-	HARDPAN	73	82
-	-	G	-	GRAVEL	82	87

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 PE ASTM A-53-B WELDED IPSCO STEEL CORP	Surface	87
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 28 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

13 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
RED CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SDK		01-20-2006
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Foundation Drain to Clearwater		26
Building Overhang		25	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 04-17-2007 Updated On: 10-15-2019 Review Status: