

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SU363		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KEES, BRAD						Phone # (920)841-2147		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 14						Town of RANTOUL						1135	
City HILBERT						State WI		Zip Code 54129				Street Address or Road Name and Number	
RIVER VIEW DR CHILTON WI						Subdivision Name				Lot #		Block #	
County Calumet		Co. Permit #		Notification # 21725342		Completed 01-24-2006		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name)				Lic. # 4225		Facility ID # (Public Wells)				44.07301 °N -88.09547 °W		OTH001	
Address KEIFENHEIM WELL DRLG & PUMP SERVICE BRILLION WI 54110-9318				Well Plan Approval #		NE SW		Section 34		Township 19 N		Range 20 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7		2. Well Type New Well				of previous unique well # constructed in			
Reason for replaced or reconstructed well ?				WELL FOR NEW HOUSE				Construction Type Drilled					
3. Well serves 1 # of Private, potable						Hicap Well ? No							
Heat Exchange ___ # of drillholes						Hicap Property ? No							
Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
10		Surface		20		Rotary - Mud Circulation				Yes			
6		20		120		Rotary - Air				Yes			
Rotary - Air & Foam													
Drill-Through Casing Hammer													
Reverse Rotary													
Cable-tool Bit ___ in. dia...													
Dual Rotary													
Temp. Outer Casing ___ in. dia													
Removed? ___ depth ft. (If NO explain on back side)													
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
R - C -				RED CLAY				Surface		60			
G - C -				GRAY CLAY				60		75			
T - C -				BROWN CLAY				75		90			
- - Y -				SAND & GRAVEL				90		105			
- - L -				LIMESTONE				105		120			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL 18.97 PE ASTM A53B WELDED IPSCO STEEL CORP				Surface		105					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material										9. Static Water Level			
Method										40 ft. below ground surface			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is					
RED CLAY SLURRY		Surface		20				16 in. above grade					
Developed ? Yes										Disinfected ? Yes			
Capped ? Yes										Pumping level 47 ft. below surface			
Pumping at 12 GP M for 2 Hrs.										Pumping Method ?			
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?										Yes			
13. Constructor / Supervisory Driller								Lic #		Date Signed			
SDK										02-10-2006			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		22	Septic or Holding, or POWTS Tank		90
			POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 03-02-2007

Updated On: 08-25-2022

Review Status: