Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SU534

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BEAR CONSTRUCTION			Phone #
Mailing Address: 2290 10 1/2 AVE			
City: CHETEK	State: WI	Zip Code: 54728	
County: Washington	Co. Permit #:	Notification #: 21241863	Completed: 10-26-2005

Well Constructor (Business Name): LAHR WELL DRLG & PUMP SERV INC	Lic. #: 6601	Facility ID # (Public Wells):	
Address: N48 W14784 LISBON RD MENOMONEE FALLS WI 53051-6916		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ERIN

Fire # (if avail.)

Street Address or Road Name and Number: 2269 POWDER HILL RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SW	SE	Section	Township	Range
or Govt Lot #		1	9 N	18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
6	15	195

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Yes Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	-	CLAY	Surface	15
T	-	Y	-	SAND & GRAVEL	15	125
G	-	Y	C	SAND, GRAVEL & CLAY	125	135
T	-	Y	-	SAND & GRAVEL	135	195

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P/E PIPE ASTM A-53 GR B IPSCO TUB 18.97# FT WELDED	Surface	192
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL 35 SLOT	192	195

7. Grout or Other Sealing Material
Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CUTTINGS & BENTONITE CRUMBLES	Surface	20	

9. Static Water Level
130 ft. below ground surface

10. Pump Test
Pumping level 160 ft. below surface
Pumping at 60 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MH		12-01-2005
Drill Rig Operator	Lic or Reg #	Date Signed
JL		10-28-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-16-2006 Updated On: 05-16-2006 Review Status: