

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SU539		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner KUETTEL, KURT & HOLLY						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address W131 N6638 CRESTWOOD						Town of RICHFIELD						Street Address or Road Name and Number 4666 PARTRIDGE CIR									
City MENOMONEE FALLS				State WI		Zip Code 53051															
County Washington		Co. Permit #		Notification # 21825457		Completed 12-15-2005		Subdivision Name WINCHESTER FLDS				Lot # 93		Block #							
Well Constructor (Business Name) LAHR WELL DRLG & PUMP SERV INC				Lic. # 6601		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2143 °N -88.271 °W				Method Code GCD013							
Address N48 W14784 LISBON RD MENOMONEE FALLS WI 53051-6916				Well Plan Approval #				NW SE		Section 29		Township 9 N		Range 19 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #		29		9 N		19 E							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
3. Well serves 1 # of Private, potable				Hicap Well ? No																	
Heat Exchange ___ # of drillholes				Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		212		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T - Y G T - Y - T - X - G - C - T - Y -				GRAVEL, SAND & STONES SAND & GRAVEL SAND & CLAY CLAY SAND & GRAVEL		Surface 75 160 198 198 208 208 212		75 160 198 208 212			
6. Casing, Liner, Screen														9. Static Water Level						11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		115 ft. below ground surface						12 in. above grade					
6		PE PIPE ASTM A53 GR B WTC 18.97# FT WELDED				Surface		212		10. Pump Test Pumping level 180 ft. below surface Pumping at 50 GP M for 1 Hrs. Pumping Method ?						Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
7. Grout or Other Sealing Material		Method MOUND				Kind of Sealing Material										From (ft.)		To (ft.)		# Sacks Cement	
BENTONITE CRUMBLES		Surface				20		20								20		20			
13. Constructor / Supervisory Driller														Lic #		Date Signed					
MH														01-04-2006		Drill Rig Operator					
ML														12-16-2005		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Clearwater Sump		60
			Downspout/Yard Hydrant		30
Building Overhang		29	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 05-02-2006

Updated On: 07-05-2019

Review Status: