Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SV046

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STASKAL, STEVEN	Phone #: (563)652-5831
Mailing Address: 4085 PROSPECT ST	
City: MAQUOKETA	State: IA — Zip Code: 52060-
County: Grant	Co. Permit #:
Notification #: 19878034	Completed: 06-27-2005
Well Constructor (Business Name): DEAN A KIRSCHBAUM	Lic. #: 6536
Facility ID # (Public Wells):	
Address: DON'S WELL DRILLING LLC, BOSCOBEL WI 53805	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Town of CLIFTON	Fire # (if avail.):
Street Address or Road Name and Number: 11270 ROCK CHURCH RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.9136 °N -90.4711 °W	Method Code: GCD013
NE NE or Govt Lot #	Section: 15 — Township: 5 N — Range: 1 W

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	168
6	168	220

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Yes / No — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 14depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	14
-	-	L	-	LIMEROCK	14	110
-	-	N	-	SANDROCK	110	150
-	-	L	-	LIMEROCK	150	220

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL WHEATLAND PIPE 6.625 OD A53B PE	Surface	168
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
130 ft. below ground surface

10. Pump Test
Pumping level 200 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	168	57 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		07-13-2005
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		36

Comment: SEPTIC/SEWER NOT IN

Created On: 07-27-2005 Updated On: 03-17-2020 Review Status: