

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SV093		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner NYHOF, DAVE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 4689 AIRPORT RD						Town of ELLENBORO													
City LANCASTER						State WI		Zip Code 53813				Street Address or Road Name and Number 4689 AIRPORT RD							
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Grant				22604814		05-05-2006													
Well Constructor (Business Name) DEAN A KIRSCHBAUM				Lic. # 6536		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.78499 °N -90.6458 °W				Method Code OTH001					
Address DON'S WELL DRILLING LLC BOSCOBEL WI 53805				Well Plan Approval #				SE NE		Section Township		Range							
				Approval Date (mm-dd-yyyy)				or Govt Lot # 31		4 N		2 W							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type New Well									
										of previous unique well # constructed in									
										Reason for replaced or reconstructed well ?									
3. Well serves 1 # of				Hicap Well ? No						Construction Type Drilled									
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 210											- - C -		CLAY		Surface 10				
6 210 280											- - L -		LIME ROCK		10 170				
			Rotary - Mud Circulation								- - N -		SAND ROCK		170 200				
			<u>Yes</u> Rotary - Air								- - L -		LIME ROCK		200 280				
			<u>Yes</u> Rotary - Air & Foam																
			Drill-Through Casing Hammer																
			Reverse Rotary																
			Cable-tool Bit ___ in. dia...																
			Dual Rotary																
			<u>Yes</u> Temp. Outer Casing 10in. dia																
			<u>Yes</u> Removed? 10depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		200 ft. below ground surface				12 in. above grade					
6		NEW BLACK STEEL IPSCO TUBULAR ASTM-A53-BP ERW				Surface		210											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes					
										Pumping level 260 ft. below surface				Disinfected ? Yes					
										Pumping at 10 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method PRESSURE TREMIE														Filled & Sealed Well(s) as needed?					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT				Surface		210		63 S		DK						05-22-2006			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		54

Comment: SEPTIC/SEWER NOT IN

Created On: 07-11-2006

Updated On: 08-25-2022

Review Status: