Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SV093

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NYHOF, DAVE	Phone #
Mailing Address: 4689 AIRPORT RD	
City: LANCASTER	State: WI — Zip Code: 53813
County: Grant	Co. Permit #: — Notification #: 22604814 — Completed: 05-05-2006
Well Constructor (Business Name): DEAN A KIRSCHBAUM	Lic. #: 6536 — Facility ID # (Public Wells):
Address: DON'S WELL DRILLING LLC, BOSCOBEL WI 53805	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of ELLENBORO

Fire # (if avail.):

Street Address or Road Name and Number: 4689 AIRPORT RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.78499 °N -90.6458 °W — Method Code: OTH001

SE NE or Govt Lot #: — Section: 31 — Township: 4 N — Range: 2 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	210
6	210	280

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes / Yes — Rotary - Air .....
- Yes / No — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	10
-	-	L	-	LIME ROCK	10	170
-	-	N	-	SAND ROCK	170	200
-	-	L	-	LIME ROCK	200	280

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL IPSCO TUBULAR ASTM-A53-BP ERW	Surface	210
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

200 ft. below ground surface

10. Pump Test

Pumping level 260 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	210	63 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		05-22-2006
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		54

Comment: SEPTIC/SEWER NOT IN

Created On: 07-11-2006 Updated On: 08-25-2022 Review Status: