Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SV202

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KA BUILDERS	Phone #: (262)620-3962
Mailing Address: PO BOX 147	
City: TWIN LAKES	State: WI — Zip Code: 53181
County: Kenosha	Co. Permit #:
Notification #: 30107476	Completed: 07-17-2008
Well Constructor (Business Name): GEORGE E GAFFKE	Lic. #: 4263
Facility ID # (Public Wells):	
Address: HENRY BOYSEN CO HAINESVILLE IL 60030	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3.8	

1. Well Location

Town of SALEM	Fire # (if avail.): 25811
Street Address or Road Name and Number: 25811 91ST ST	
Subdivision Name: FALCON HEIGHTS	Lot #: 5 — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.5428 °N -88.1216 °W	Method Code: GCD013
SE SW or Govt Lot #:	Section: 15 — Township: 1 N — Range: 20 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	96

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	-	BROWN CLAY	Surface	14
U	-	C	-	BLUE CLAY	14	86
-	-	Y	-	SAND & GRAVEL	86	96

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC DR21 F480 CRNTEED GLUE JT	Surface	93
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	304 STAINLESS SLOT .010	93	96

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GROUT PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	93	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GEG		07-29-2008
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DR		07-29-2008

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Collector Sewer - San or Storm		125
			Sewer - Building Sanitary		44

Comment:

Created On: 09-29-2008 Updated On: 09-16-2026 Review Status: