Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SV523

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALLACE, ARLENE			Phone #: (608)734-3676
Mailing Address: BOX 154			
City: FERRYVILLE	State: WI	Zip Code: 54628	
County: Crawford	Co. Permit #:	Notification #: 27298049	Completed: 10-05-2007

Well Constructor (Business Name): NORMAN HOLLER	Lic. #: 252	Facility ID # (Public Wells):	
Address: HOLLER PLBG & WELL DRLG, LA CROSSE WI 54601		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of FERRYVILLE

Fire # (if avail.): 154

Street Address or Road Name and Number: 154 FERRYVILLE

Subdivision Name	Lot #	Block #
	7-8	2

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NW or Govt Lot #	NW	Section	Township	Range
		16	10 N	6 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	17	59
8	Surface	17
6	59	85

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 8in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- Yes — Removed? 17depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	16
-	-	H	-	SHALE	16	54
-	-	N	-	SANDROCK	54	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK PLAINE END AMTA53 WHEATLAND	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method TREMIE PIPE PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	59	51 S

9. Static Water Level
42 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 12 GP M for 16 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
NH		10-25-2007
Drill Rig Operator	Lic or Reg #	Date Signed
MH		10-25-2007

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		4	Collector Sewer - San or Storm		50
			Sewer - Building Sanitary		50

Comment:

Created On: 01-17-2008 Updated On: 01-17-2008 Review Status: