

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SV523		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WALLACE, ARLENE						Phone # (608)734-3676		1. Well Location				Fire # (if avail.)			
Mailing Address BOX 154						Town of FERRYVILLE						154			
City FERRYVILLE						State WI		Zip Code 54628				Street Address or Road Name and Number			
City FERRYVILLE						State WI		Zip Code 54628				154 FERRYVILLE			
County Crawford		Co. Permit #		Notification # 27298049		Completed 10-05-2007		Subdivision Name				Lot # 7-8		Block # 2	
Well Constructor (Business Name) NORMAN HOLLER				Lic. # 252		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address HOLLER PLBG & WELL DRLG LA CROSSE WI 54601				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		NW NW Section Township Range or Govt Lot # 16 10 N 6 W					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7		2. Well Type New Well							
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		of previous unique well # constructed in							
Private, potable				Hicap Potable ?		Construction Type Drilled		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of															
Heat Exchange ___ # of drillholes															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 17 59			Rotary - Mud Circulation												
8 Surface 17			Rotary - Air												
6 59 85			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Yes Cable-tool Bit 8in. dia... No												
			Dual Rotary												
			Yes Temp. Outer Casing 8in. dia												
			Yes Removed? 17depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		BLACK PLAINE END AMTA53 WHEATLAND				Surface 63									
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method TREMIE PIPE PUMP															
Kind of Sealing Material				From (ft.) To (ft.) # Sacks Cement											
CEMENT				Surface 59 51 S											
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)									
- - C -		CLAY				Surface 16									
- - H -		SHALE				16 54									
- - N -		SANDROCK				54 85									
9. Static Water Level															
42 ft. below ground surface															
10. Pump Test															
Pumping level 60 ft. below surface															
Pumping at 12 GP M for 16 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
NH				10-25-2007											
Drill Rig Operator				Lic or Reg #											
MH				Date Signed											
				10-25-2007											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		4	Collector Sewer - San or Storm		50
			Sewer - Building Sanitary		50

Comment:

Created On: 01-17-2008

Updated On: 01-17-2008

Review Status: