Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SV524

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SALEK, CARL	Phone #: (608)634-3328
Mailing Address: W588 CO RD P	
City: WESTBY	State: WI — Zip Code: 54667
County: La Crosse	Co. Permit #: 4334 — Notification #: 27298067 — Completed: 10-22-2007
Well Constructor (Business Name): NORMAN HOLLER	Lic. #: 252 — Facility ID # (Public Wells):
Address: HOLLER PLBG & WELL DRLG, LA CROSSE WI 54601	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.4

1. Well Location

Town of WASHINGTON				Fire # (if avail.): W588
Street Address or Road Name and Number: W588 CO HWY P				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NE NW or Govt Lot #:	Section: 35	Township: 15 N	Range: 5 W	

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.5	Surface	78
6	78	80
6	82	110

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 8in. dia... Yes
- Dual Rotary .....
- Yes Temp. Outer Casing 8in. dia
- Yes Removed? 21depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	15
-	-	G	-	ROCK, OPEN LEDGE	15	23
-	-	H	-	SHALE ROCK	23	73
-	B	N	-	BROKEN ROCK	73	78
-	-	N	-	SAND ROCK	78	110

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK PLAIN END AMT A53 WHEELING	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	78	42 S

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 12 GP M for 10 Hrs.
Pumping Method ?

11. Well Is
22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
NH		11-08-2007
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110
Building Drain - Sanitary		40
Building Overhang		12
Foundation Drain to Clearwater		40
Foundation Drain to Sewer		40
Sewer - Building Sanitary		100
Septic or Holding, or POWTS Tank		102

Comment:

Created On: 08-05-2008 Updated On: 08-13-2008 Review Status: