

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SV766		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner AMBROZ, GAIL						Phone # (262)835-2705		1. Well Location				Fire # (if avail.)					
Mailing Address 8938 6 MILE RD						Town of CALEDONIA						Street Address or Road Name and Number 8938 6 MILE RD					
City CALEDONIA				State WI		Zip Code 53108											
County Racine		Co. Permit #		Notification # 35315297		Completed 12-14-2009		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) MAY L L WELL DRILLING CO INC				Lic. # 9		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8145 °N -87.8944 °W			Method Code GCD013				
Address 9112 S 13TH ST OAK CREEK WI 53154-4302				Well Plan Approval #				SW SW Section Township Range or Govt Lot # 10 4 N 22 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? IN WAY OF MOUND SYSTEM							
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #			Common Well #			Specific Capacity 0.5			Construction Type Drilled								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 10in. dia... No Dual Rotary Yes Temp. Outer Casing 10in. dia Yes Removed? ___depth ft. (If NO explain on back side)		- - C - CLAY - - P - HARDPAN - - S - SAND - - L - LIMESTONE		Surface		40					
6		20		160						40		83					
										83		84					
										84		160					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface							
6		NEW, STEEL, WELDED ASTM A-53 18.97LB/FT WHEATLAND STEEL				Surface		84		Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
										10. Pump Test Pumping level 70 ft. below surface Pumping at 15 GP M for 23 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method						Filled & Sealed Well(s) as needed? Yes SEE FILE #3300											
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
DRILL CUTTINGS-MUD		Surface		20		S											
						13. Constructor / Supervisory Driller											
						Lic #		Date Signed									
DM								12-19-2009									
Drill Rig Operator						Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		20
Building Drain - Sanitary		35	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 02-18-2010

Updated On: 06-28-2019

Review Status: