

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SW598		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WINTER, ROGER						Phone # (715)466-2912		1. Well Location				Fire # (if avail.)					
Mailing Address 7325 E CO RD T						Town of WASCOTT						7325					
City MINONG						State WI		Zip Code 54859				Street Address or Road Name and Number CO RD T					
County Douglas		Co. Permit #		Notification # 22261364		Completed 04-17-2006		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) JOHN H HOYER				Lic. # 5747		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.1726 °N -91.9169 °W				Method Code GCD013			
Address 7505 E FLOWAGE RD MINONG WI 54859				Well Plan Approval #		SE SW		Section 30		Township 43 N		Range 12 W		or Govt Lot #			
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 2				2. Well Type New Well					
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?				of previous unique well # constructed in							
Heat Exchange ___ # of drillholes				Construction Type Drilled		3. Well serves 1 # of Private, potable				4. Potential Contamination Sources - ON REVERSE SIDE							
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		14		Rotary - Mud Circulation				- - S -		SAND		Surface		18	
4		14		56		Rotary - Air				- - X -		CLAY & SAND		18		45	
						Rotary - Air & Foam				- - Y -		SAND & GRAVEL		45		56	
						Drill-Through Casing Hammer											
						Reverse Rotary											
						<u>Yes</u> Cable-tool Bit 4in. dia...		<u>No</u>									
						<u>Yes</u> Dual Rotary											
						<u>Yes</u> Temp. Outer Casing 8in. dia											
						<u>Yes</u> Removed? ___depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		16 ft. below ground surface				13 in. above grade			
6		STEEL T&C 11.00 LBS IPSCO A53				Surface		56		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 26 ft. below surface				Disinfected ? Yes			
4		SS 15 SLOT				53		56		Pumping at 20 GP M for 1 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method						Filled & Sealed Well(s) as needed?											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller		Lic #		Date Signed			
BENTONITE		Surface		14		2 S				JH				04-27-2006			
										Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Shoreline/Pool		100
Building Overhang		12	Sewer - Building Sanitary		25
Foundation Drain to Sewer		25	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 05-16-2006

Updated On: 06-25-2020

Review Status: