Well Construction Report
WISCONSIN UNIQUE WELL NUMBER SW657

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	EAGEN, RICHARD
Phone #	
Mailing Address	101839 WOODLAND RD
City	LAKE GENEVA
State	WI
Zip Code	53147
County	Walworth
Co. Permit #	
Notification #	19873796
Completed	06-14-2005
Well Constructor (Business Name)	GEHRING LANCE WELL DRILLING SER
Lic. #	6740
Facility ID # (Public Wells)	
Address	5506 353RD AVE BURLINGTON WI 53105
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	0.5

1. Well Location

Town of LINN	
Fire # (if avail.)	
Street Address or Road Name and Number	N1839 WOODLAND RD
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	42.5592 °N -88.5043 °W
Method Code	GCD013
NE SE or Govt Lot #	
Section	8
Township	1 N
Range	17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

OFF COMMUNITY WELL

Construction Type Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	148

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — No

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	99
-	-	G	-	GRAVEL	99	107
-	-	X	-	CLAY SAND	107	144
-	-	Y	-	SAND GRAVEL	144	148

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	200 LB PVC 1120 ASTME480 SOR 21 CERTANTEED SOLVENT	Surface	144
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS STEEL #20	144	148

7. Grout or Other Sealing Material

Method PRESSURE PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROID QUICK GROUT	Surface	144	14 S

9. Static Water Level

91 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
LG		06-14-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 07-26-2005 Updated On: 09-12-2019 Review Status: