

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				SY309		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner GERBER, JERRY						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 2041 21 15/16 ST						Town of CHETEK						Street Address or Road Name and Number					
City RICE LAKE				State WI		Zip Code 54868-											
County Barron		Co. Permit #		Notification #		Completed 04-30-2005		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) THOM J RUTHERFORD				Lic. # 4719		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address RUTHERFORD WELL DRLG RICE LAKE WI 54868				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range					
								SW SE		Section 18				Township 33 N			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4		2. Well Type New Well									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		of previous unique well # constructed in											
						Reason for replaced or reconstructed well ?											
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled											
						5. Drillhole Dimensions and Construction Method											
Dia. (in.) 4		From (ft.) Surface		To (ft.) 79		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		T Q S G		R - X G		R - Z P		T N S -		BROWN CAVING SAND GRAVEL RED CLAY LAYERS SND GRAVEL HARD PAN GRAVEL CLAY RED BROWN FINE SAND BLACK SPEC		Surface 16 26 26 46 46 79		16 26 46 79			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.) 4		Material, Weight, Specification IPSCO ASTM A53B 1079 234 WELDED				From (ft.) Surface		To (ft.) 75		33 ft. below ground surface				15 in. above grade			
Dia. (in.) 3		Screen type, material & slot size STAINLESS #10 SLOTTED				From (ft.) 75		To (ft.) 79		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material Method BENTONITE MOUNDED		Kind of Sealing Material		From (ft.) Surface		To (ft.)		# Sacks Cement		Pumping level 65 ft. below surface Pumping at 12 GP M for 48 Hrs. Pumping Method ?							
		Filled & Sealed Well(s) as needed?		No WERE NONE													
12. Notified Owner of need to fill & seal ?						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						TR				05-30-2005							
						Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	Sewer - Building Sanitary		40
Building Overhang		12	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 06-09-2005

Updated On: 06-09-2005

Review Status: