Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TA236

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SINGER, CHARLES	Phone #: (763)818-9327
Mailing Address: 4519 ARDAN AVE S	
City: EDINA	State: MN — Zip Code: 55424
County: Burnett	Co. Permit #:
Notification #: 24423157	Completed: 12-27-2006
Well Constructor (Business Name): MARTIN WELL DRLG LLC	Lic. #: 7087
Facility ID # (Public Wells):	
Address: 522N CTY HWY F, BIRCHWOOD WI 54817	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.6	

1. Well Location

Town of WEBB LAKE

Fire # (if avail.):

Street Address or Road Name and Number: S WEBB LAKE DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW	NE	Section	Township	Range
or Govt Lot #		17	41 N	14 W

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	47

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - S -	BROWN SAND	Surface	35
- A S -	COARSE SAND	35	47

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PE 10.79# ASTM A53A IPSCO USA	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	SS #10	43	47

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

27 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 8 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DH		01-11-2007
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
IM		01-01-2007

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		106	Sewer - Building Sanitary		67
Building Overhang		35	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 03-20-2007 Updated On: 08-23-2016 Review Status: