Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TA269

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NESTE, LARRY	Phone #: (715)635-2651
Mailing Address: 705 1ST RD	
City: SPOONER	State: WI — Zip Code: 54801
County: Washburn	Co. Permit #:
Notification #: 21252918	Completed: 11-01-2005
Well Constructor (Business Name): CHRISTOPHER LINDSTROM	Lic. #: 6521
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: LINDSTROM WELLS SPOONER WI 54801-9438	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of SPRINGBROOK

Fire # (if avail.):

Street Address or Road Name and Number: HWY 63

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SE or Govt Lot #: | Section: 22 | Township: 40 N | Range: 11 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	91

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - S -	BROWN SAND	Surface	32
T - C -	BROWN CLAY	32	64
T - M -	BROWN SILT	64	85
T - Y -	BROWN SAND & GRAVEL	85	91

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	A53B .258 WALL 2210 PSI PLAIN END IPSCO	Surface	87
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS #10	87	91

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

62 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CPL		11-01-2005
Drill Rig Operator	Lic or Reg #	Date Signed
EL		11-01-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-18-2006 Updated On: 01-18-2006 Review Status: