

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TA269		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner NESTE, LARRY					Phone # (715)635-2651		1. Well Location				Fire # (if avail.)				
Mailing Address 705 1ST RD					Town of SPRINGBROOK					Street Address or Road Name and Number HWY 63					
City SPOONER			State WI		Zip Code 54801										
County Washburn		Co. Permit #		Notification # 21252918		Completed 11-01-2005		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) CHRISTOPHER LINDSTROM				Lic. # 6521		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code				
Address LINDSTROM WELLS SPOONER WI 54801-9438				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 22 40 N 11 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #			Common Well #		Specific Capacity 0.7		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
5		Surface		91		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
T		-		S				-		BROWN SAND		Surface		32	
T		-		C				-		BROWN CLAY		32		64	
T		-		M				-		BROWN SILT		64		85	
T		-		Y				-		BROWN SAND & GRAVEL		85		91	
6. Casing, Liner, Screen		Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			11. Well Is
5		A53B .258 WALL 2210 PSI PLAIN END IPSCO		Surface		87		62 ft. below ground surface			18 in. above grade				
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)		10. Pump Test			Developed ? Yes Disinfected ? Yes Capped ? Yes				
4		STAINLESS #10		87		91		Pumping level 80 ft. below surface Pumping at 12 GP M for 24 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material								12. Notified Owner of need to fill & seal ?							
Method								Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)								# Sacks Cement	
Surface				87		91		13. Constructor / Supervisory Driller		Lic #		Date Signed			
CPL				87		91		Drill Rig Operator		Lic or Reg #		Date Signed			
EL				87		91		11-01-2005		11-01-2005		11-01-2005			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 01-18-2006

Updated On: 01-18-2006

Review Status: