Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TA271

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LUCAS CONST			Phone #: (715)520-2077
Mailing Address: 105 BALSAM ST			
City: SPOONER	State: WI	Zip Code: 54801	
County: Washburn	Co. Permit #:	Notification #: 21689909	Completed: 11-17-2005

Well Constructor (Business Name): CHRISTOPHER LINDSTROM	Lic. #: 6521	Facility ID # (Public Wells):
Address: LINDSTROM WELLS SPOONER WI 54801-9438		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6

1. Well Location

Town of CASEY

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:		
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:	
NW NE or Govt Lot #:	Section: 26	Township: 40 N	Range: 13 W	

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	72

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	-	BROWN CAVING SAND	Surface	45
T	-	P	-	BROWN HARDPAN	45	60
T	-	Y	-	BROWN SAND & GRAVEL	60	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	A53B .258 WALL 2210 PSI PLAIN END IPSCO	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS #10	68	72

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 12 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
CPL		11-17-2005
Drill Rig Operator	Lic or Reg #	Date Signed
EL		11-17-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-18-2006 Updated On: 01-18-2006 Review Status: