

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TA271		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LUCAS CONST						Phone # (715)520-2077		1. Well Location				Fire # (if avail.)	
Mailing Address 105 BALSAM ST						Town of CASEY						Street Address or Road Name and Number	
City SPOONER				State WI		Zip Code 54801							
County Washburn		Co. Permit #		Notification # 21689909		Completed 11-17-2005		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) CHRISTOPHER LINDSTROM				Lic. # 6521		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code		
Address LINDSTROM WELLS SPOONER WI 54801-9438				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 26 40 N 13 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
Approval Date (mm-dd-yyyy)				Hicap Permanent Well # Common Well # Specific Capacity 0.6									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
5		Surface		72		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)					
T Q S -			BROWN CAVING SAND			Surface		45					
T - P -			BROWN HARDPAN			45		60					
T - Y -			BROWN SAND & GRAVEL			60		72					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
5		A53B .258 WALL 2210 PSI PLAIN END IPSCO				Surface		68					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		STAINLESS #10				68		72					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
Surface				Surface		Surface		Surface					
9. Static Water Level													
40 ft. below ground surface													
10. Pump Test													
Pumping level 60 ft. below surface													
Pumping at 12 GP M for 24 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
CPL								Lic #		Date Signed 11-17-2005			
Drill Rig Operator								Lic or Reg #		Date Signed 11-17-2005			
EL								EL		EL			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-18-2006

Updated On: 01-18-2006

Review Status: