

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TA838		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FLEURY, GENEVIEVE & BRUCE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address E BIRCH DR						Town of ROME									
City OAK CREEK						State WI		Zip Code 53154				Street Address or Road Name and Number 1643 ASPEN AVE			
County Adams		Co. Permit #		Notification # 22308018		Completed 05-18-2006		Subdivision Name BIG BUCK ACS				Lot # 13		Block #	
Well Constructor (Business Name) RAY E FOSTER				Lic. # 164		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 2502 STATE RD 13 ADAMS WI 53910-9739				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NE Section Township Range or Govt Lot # 34 20 N 5 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Jetted					
Hicap Permanent Well #		Common Well #		Specific Capacity		Hicap Well ? No		Hicap Property ? No		Hicap Potable ?					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		6		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
2		6		67											
8. Geology															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
2		SEAH ASTM A53A 3.75 THREADED & COUPLED		Surface		63		- - S - - A Y -		SAND COARSE SAND & GRAVEL		Surface 30		30 67	
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)									
1.25		CAMPBELL SS 10 SLOT		63		67									
6. Casing, Liner, Screen															
9. Static Water Level															
32 ft. below ground surface															
10. Pump Test															
Pumping level 32 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?															
11. Well Is															
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
PITLESS ADPT		Surface		6											
13. Constructor / Supervisory Driller															
DSF															
Drill Rig Operator															
Date Signed 06-23-2006															
Lic #															
Lic or Reg #															
Date Signed															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53	Wastewater Sump		33
Building Drain - Sanitary		27	Sewer - Building Sanitary		35
Building Overhang		6	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 07-14-2006

Updated On: 07-14-2006

Review Status: