Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TA838

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FLEURY, GENEVIEVE & BRUCE			Phone #
Mailing Address: E BIRCH DR			
City: OAK CREEK	State: WI	Zip Code: 53154	
County: Adams	Co. Permit #:	Notification #: 22308018	Completed: 05-18-2006

1. Well Location

Town of ROME

Fire # (if avail.)

Street Address or Road Name and Number: 1643 ASPEN AVE

Subdivision Name: BIG BUCK ACS	Lot #: 13	Block #

Well Constructor (Business Name): RAY E FOSTER	Lic. #: 164	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD) °N °W — Method Code

Address: 2502 STATE RD 13
ADAMS WI 53910-9739

Well Plan Approval #

Approval Date (mm-dd-yyyy)

NW	NE	Section	Township	Range
or Govt Lot #		34	20 N	5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	67

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	30
-	A	Y	-	COARSE SAND & GRAVEL	30	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SEAH ASTM A53A 3.75 THREADED & COUPLED	Surface	63
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	CAMPBELL SS 10 SLOT	63	67

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PITLESS ADPT	Surface	6	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DSF		06-23-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53	Wastewater Sump		33
Building Drain - Sanitary		27	Sewer - Building Sanitary		35
Building Overhang		6	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 07-14-2006 Updated On: 07-14-2006 Review Status: