

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TB600		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BEYERS, DAN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 36720 128TH ST						Town of BLOOMFIELD						Street Address or Road Name and Number W1833 DAISY							
City TWIN LAKES				State WI		Zip Code 53181													
County Walworth		Co. Permit #		Notification # 23164773		Completed 09-08-2006		Subdivision Name				Lot # 1		Block #					
Well Constructor (Business Name) THOMAS J WILTON				Lic. # 132		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5571 °N -88.3411 °W				Method Code GCD013					
Address WILTON WELL DRILLING SALEM WI 53168-0172				Well Plan Approval #				NW SW Section Township Range or Govt Lot # 11 1 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		Surface		60		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 5in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- Q G - G V C - - - S -		GRAVEL C GRAY CLAY NC SAND		Surface 35 50 60		35 50 60			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				20 in. above grade					
5		BLK T&C ASTMA 53 1950 PSI TRI STATE				Surface		56		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
4		DOC SLOTED MONOFLEX 20				56		60											
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller TJW Drill Rig Operator JF				Lic # Lic or Reg # Date Signed 09-11-2006 Date Signed 09-11-2006			
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
#8 BENTONITE				Surface		60													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		30
Building Overhang		24	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-17-2006

Updated On: 09-12-2019

Review Status: