Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TB600

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BEYERS, DAN			Phone #
Mailing Address: 36720 128TH ST			
City: TWIN LAKES	State: WI	Zip Code: 53181	
County: Walworth	Co. Permit #:	Notification #: 23164773	Completed: 09-08-2006

1. Well Location

Fire # (if avail.):

Town of BLOOMFIELD

Street Address or Road Name and Number: W1833 DAISY

Subdivision Name	Lot #	Block #
	1	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
THOMAS J WILTON	132	

Address: WILTON WELL DRILLING, SALEM WI 53168-0172

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Latitude / Longitude in Decimal Degree (DD): 42.5571 °N -88.3411 °W

Method Code: GCD013

NW SW or Govt Lot #	Section	Township	Range
	11	1 N	18 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Hicap Permanent Well #:

Common Well #:

Specific Capacity:

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 5in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- Q G -	GRAVEL C	Surface	35
G V C -	GRAY CLAY NC	35	50
- - S -	SAND	50	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLK T&C ASTMA 53 1950 PSI TRI STATE	Surface	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	DOC SLOTED MONOFLEX 20	56	60

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface	60	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJW		09-11-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF		09-11-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		30
Building Overhang		24	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-17-2006 Updated On: 09-12-2019 Review Status: