Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TD076

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GAYNOR, ROBIN			Phone #
Mailing Address: 37710 53RD ST			
City: WHEATLAND	State: WI	Zip Code: 53152	
County: Kenosha	Co. Permit #:	Notification #: 23877526	Completed: 12-15-2006

1. Well Location

Town of WHEATLAND

Fire # (if avail.)

Street Address or Road Name and Number: 37110 53RD ST

Subdivision Name	Lot #	Block #
KOCHS	8	5

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
THOMAS J WILTON	132	

Latitude / Longitude in Decimal Degree (DD): 42.589 °N -88.261 °W

Method Code: GCD013

Well Plan Approval #:

NE	SW	Section	Township	Range
or Govt Lot #		33	2 N	19 E

Address: WILTON WELL DRILLING, SALEM WI 53168-0172

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	89

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 5in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	Y	-	SAND & GRAVEL	Surface	55
T	V	C	-	BRN CLAY NC	55	75
-	-	S	-	SAND	75	89

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLK T&C ASTMA 53 1950 PSI TRI STATE	Surface	85
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	PVC SLOTTEN MONO FLEX 20	85	89

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface	89	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJW		12-18-2006
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LF		12-18-2006

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Sewer - Building Sanitary		62
Building Overhang		20	Septic or Holding, or POWTS Tank		66

Comment:

Created On: 01-23-2007 Updated On: 08-23-2019 Review Status: