

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TD076		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner GAYNOR, ROBIN						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 37710 53RD ST						Town of WHEATLAND															
City WHEATLAND						State WI		Zip Code 53152													
County Kenosha		Co. Permit #		Notification # 23877526		Completed 12-15-2006		Subdivision Name KOCHS				Lot # 8 Block # 5									
Well Constructor (Business Name) THOMAS J WILTON				Lic. # 132		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.589 °N -88.261 °W				Method Code GCD013									
Address WILTON WELL DRILLING SALEM WI 53168-0172				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE SW		Section 33		Township 2 N		Range 19 E							
								or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
3. Well serves 1 # of				Hicap Well ? No																	
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		Surface		89										- Q Y -		SAND & GRAVEL		Surface		55	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary								T V C -		BRN CLAY NC		55		75	
						Yes Cable-tool Bit 5in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								- - S -		SAND		75		89	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		55 ft. below ground surface				20 in. above grade							
5		BLK T&C ASTMA 53 1950 PSI TRI STATE				Surface		85		10. Pump Test Pumping level 55 ft. below surface Pumping at 15 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
4		PVC SLOTTEN MONO FLEX 20				85		89													
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
#8 BENTONITE				Surface		89															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TJW						12-18-2006	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														LF						12-18-2006	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Sewer - Building Sanitary		62
Building Overhang		20	Septic or Holding, or POWTS Tank		66

Comment:

Created On: 01-23-2007

Updated On: 08-23-2019

Review Status: