

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TD338		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner GILLMORE, RONALD						Phone # (262)620-4162		1. Well Location				Fire # (if avail.)		
Mailing Address 11315 HORTON RD						Town of BRISTOL						Street Address or Road Name and Number 11315 HORTON RD		
City BRISTOL				State WI		Zip Code 53104								
County Kenosha		Co. Permit #		Notification # 30309152		Completed 09-19-2008		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) GLENN E H & SONS INC				Lic. # 178		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code		
Address PO BOX 341 ANTIOCH IL 60002-0341				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		Section Township Range 35 1 N 21 E		NW NW or Govt Lot #		
								NW NW or Govt Lot #						
Hicap Permanent Well #				Common Well #		Specific Capacity 0.8		2. Well Type New Well						
3. Well serves 1 # of Private, potable						Hicap Well ? No		of previous unique well # constructed in						
Heat Exchange ___ # of drillholes						Hicap Property ? No		Reason for replaced or reconstructed well ?						
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
4		Surface		206		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				No				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology				
4		GALV STEEL 11 LBS PER FT ASTM A-53-B PUSAN T&C				Surface		206						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method GRAVITY														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		9. Static Water Level 85 ft. below ground surface				
GRANULAR BENTONITE				Surface		5 S		5 S						
GRANULAR BENTONITE				Surface		5 S		5 S						
10. Pump Test														
Pumping level 100 ft. below surface														
Pumping at 12 GP for 6 Hrs.														
Pumping Method ?														
11. Well Is														
18 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
NONE TO SEAL														
13. Constructor / Supervisory Driller														
Lic #														
Date Signed														
09-30-2008														
Drill Rig Operator														
Lic or Reg #														
Date Signed														
09-30-2008														

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		26	Foundation Drain to Clearwater		28
Clearwater Sump		85	Wastewater Sump		88
Downspout/Yard Hydrant		26	Sewer - Building Sanitary		85
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 10-30-2008

Updated On: 10-30-2008

Review Status: