

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TE331		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DANIELS					Phone # (262)989-6451		1. Well Location				Fire # (if avail.)		
Mailing Address 801 248TH AVE							Town of WHEATLAND						
City KANSASVILLE					State WI		Zip Code 53139						
County Kenosha		Co. Permit #		Notification # 25283567		Completed 03-20-2007		Subdivision Name OAKWOOD SHRS				Lot # Block #	
Well Constructor (Business Name) DAVID B ROCK				Lic. # 5823		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5675 °N -88.189 °W		Method Code GCD013	
Address ROCK-WELL WELL & PUMP SERVICE KANSASVILLE WI 53139-9702				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 12 1 N 19 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 4									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) 6		From (ft.) Surface		To (ft.) 43		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 6in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Geology Codes G S C C T W Y -		Type, Caving/Noncaving, Color, Hardness, etc... BLUE CLAY GRAVEL/SAND			
6. Casing, Liner, Screen													
Dia. (in.) 6		Material, Weight, Specification STEEL 19.45 LBS/FT IPSCO ASTM A53 6.625X.280 T/C				From (ft.) Surface		To (ft.) 43		9. Static Water Level 5 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method MOUND													
Kind of Sealing Material CRUMBLES		From (ft.) Surface		To (ft.) 42		# Sacks Cement S		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?					
13. Constructor / Supervisory Driller DR								Lic #		Date Signed 05-14-2007			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		9	Foundation Drain to Clearwater		9
Septic or Holding, or POWTS Tank		60	Sewer - Building Sanitary		15
			Clearwater Sump		17

Comment:

Created On: 09-12-2007

Updated On: 08-23-2019

Review Status: