Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TE332

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DANIELS, DALE			Phone #: (262)989-6451
Mailing Address: 801 248TH AVE			
City: KANSASVILLE	State: WI	Zip Code: 53139	
County: Kenosha	Co. Permit #:	Notification #: 25283582	Completed: 09-07-2007

Well Constructor (Business Name): DAVID B ROCK	Lic. #: 5823	Facility ID # (Public Wells):	
Address: ROCK-WELL WELL & PUMP SERVICE KANSASVILLE WI 53139-9702		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WHEATLAND

Fire # (if avail.):

Street Address or Road Name and Number: 7503 313TH AVE

Subdivision Name: OAKWOOD SHRS	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.5677 °N -88.189 °W
Method Code: GCD013

NE NE or Govt Lot #	Section: 12	Township: 1 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	45

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
U S C -	BLUE CLAY	Surface	43
T W Y -	SAND/GRAVEL	43	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 19.45 LBS/FT IPSCO ASTM A53 6.625 X .I80 T/C	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 10 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DR		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Foundation Drain to Clearwater		8
Clearwater Sump		25	Wastewater Sump		25
			Sewer - Building Sanitary		20

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Separation Distance Variance	05/18/2010	EXISTING WELL < REQUIRED 8' FROM A BUILDING FOUNDATION DRAIN

Created On: 04-17-2008 Updated On: 08-23-2019 Review Status: