Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TE334

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: VLASIN, MARY	Phone #: (262)514-4830
Mailing Address: 27101 NOTTINGHAM	
City: WATERFORD	State: WI — Zip Code: 53185
County: Racine	Co. Permit #:
Notification #: 34399481	Completed: 09-14-2009
Well Constructor (Business Name): DAVID B ROCK	Lic. #: 5823
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: ROCK-WELL WELL & PUMP SERVICE, KANSASVILLE WI 53139-9702	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.5	

1. Well Location
Town of DOVER
Fire # (if avail.):
Street Address or Road Name and Number: 4303 S BEAUMONT AVE
Subdivision Name: Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:
NW NW or Govt Lot # — Section: 35 — Township: 3 N — Range: 20 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
GETTING OFF NEIGHBORS WELL
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	100

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 6in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	-	BROWN CLAY	Surface	7
U	-	C	-	BLUE CLAY	7	75
-	W	X	-	SAND/CLAY/WATER	75	80
-	-	X	-	CLAY/SAND	80	95
-	-	S	-	SAND	95	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 19.45 LBS/FT IPSCO ASTM A53 6.625 X .280 T/C	Surface	97
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	STAINLESS 3-FT #20	97	100

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 15 GP for 24 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES	Surface		

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DR		09-30-2009
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		38	Collector Sewer - San or Storm		70
Clearwater Sump		50	Foundation Drain to Clearwater		38
			Sewer - Building Sanitary		16

Comment:

Created On: 10-22-2009 Updated On: 10-22-2009 Review Status: