

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TE546		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner HUXHOLD BUILDERS LLC						Phone # 6577330		1. Well Location				Fire # (if avail.)									
Mailing Address 5300 GREENBAY RD						Town of SOMERS						Street Address or Road Name and Number									
City KENOSHA						State WI		Zip Code 53144				8315 10TH PL									
County Kenosha		Co. Permit #		Notification # 21010714		Completed 10-01-2005		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) THOMAS L SCHULTZ				Lic. # 6643		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.6441 °N -87.9098 °W				Method Code GCD013							
Address 124 HILLSIDE DR TWIN LAKES WI 53181-9785				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE SW		Section 9		Township 2 N		Range 22 E							
								or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
3. Well serves 1 # of				Hicap Well ? No																	
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		179		Yes Rotary - Mud Circulation		No		T - C -		BROWN CLAY		Surface		4					
						Rotary - Air				- - G P		GRAVEL HARDPAN		4		12					
						Rotary - Air & Foam				G C P		GREY CLAY HARDPAN; GREY CLAY		12		133					
						Drill-Through Casing Hammer				G - C P		GRAY CLAY HARDPAN		133		174					
						Reverse Rotary				- - Y -		SAND & GRAVEL		174		179					
						Cable-tool Bit ___ in. dia...															
						Dual Rotary															
						Temp. Outer Casing ___ in. dia															
						Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				12 in. above grade							
5		ID NEW PVC CERTAINTED 1120 SDR 21 PWD 2241				Surface		174		10. Pump Test				Developed ? Yes							
										Pumping level 120 ft. below surface				Disinfected ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 12 GP M for 1 Hrs.				Capped ? Yes							
5		ID 5 FT X 5 INCH PVC JOHNSON CONTINUOUS .10 SLOT WRAPPED				174		179		Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?									
Method PUMPED												Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller						Lic #		Date Signed			
GROUT WELL DF				Surface		174		16 S		TLS								10-04-2005			
																Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		40	Clearwater Sump		60
Building Overhang		20	Collector Sewer - San or Storm		150
			Sewer - Building Sanitary		45

Comment:

Created On: 11-08-2005

Updated On: 08-23-2019

Review Status: