Well Construction Report
WISCONSIN UNIQUE WELL NUMBER TE546

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HUXHOLD BUILDERS LLC			Phone #: 6577330
Mailing Address: 5300 GREENBAY RD			
City: KENOSHA	State: WI	Zip Code: 53144	
County: Kenosha	Co. Permit #:	Notification #: 21010714	Completed: 10-01-2005

1. Well Location

Town of SOMERS

Fire # (if avail.)

Street Address or Road Name and Number: 8315 10TH PL

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
THOMAS L SCHULTZ	6643	

Latitude / Longitude in Decimal Degree (DD): 42.6441 °N -87.9098 °W

Method Code: GCD013

Well Plan Approval #:

NE	SW	Section	Township	Range
or Govt Lot #		9	2 N	22 E

Address: 124 HILLSIDE DR
TWIN LAKES WI 53181-9785

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.3

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	179

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	C	-	BROWN CLAY	Surface	4
-	-	G	P	GRAVEL HARDPAN	4	12
G		C	P	GREY CLAY HARDPAN; GREY CLAY	12	133
G	-	C	P	GRAY CLAY HARDPAN	133	174
-	-	Y	-	SAND & GRAVEL	174	179

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	ID NEW PVC CERTAINTEED 1120 SDR 21 PWD 2241	Surface	174
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	ID 5 FT X 5 INCH PVC JOHNSON CONTINUOUS .10 SLOT WRAPPED	174	179

9. Static Water Level

80 ft. below ground surface

10. Pump Test

Pumping level 120 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GROUT WELL DF	Surface	174	16 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TLS		10-04-2005
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		40	Clearwater Sump		60
Building Overhang		20	Collector Sewer - San or Storm		150
			Sewer - Building Sanitary		45

Comment:

Created On: 11-08-2005 Updated On: 08-23-2019 Review Status: