

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				TH065		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner FORMANKIEWICZ, ROBERT				Phone # (608)751-0426		1. Well Location				Fire # (if avail.)	
Mailing Address 542 BAY DR						Town of BELOIT					
City BELOIT				State WI		Zip Code 53511					
County Rock		Co. Permit #		Notification # 6515282901		Completed 08-05-2016		Subdivision Name HERON BAY		Lot # 1 Block #	
Well Constructor (Business Name) CHARLES WADE MARTIN				Lic. # 6623		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.5743 °N -89.0422 °W		Method Code GCD013	
Address 1192 PRAIRIE LN MACHESNEY PARK IL 61115				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 2 1 N 12 E					
Hicap Permanent Well #		Common Well #		Specific Capacity 2.9		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) 5		From (ft.) Surface		To (ft.) 87		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes T - S - BROWN SAND T - Y - BROWN SAND & GRAVEL G - S G GRAY SAND & BROWN GRAVEL	
6. Casing, Liner, Screen											
Dia. (in.) 5		Material, Weight, Specification Manufacturer & Method of Assembly T&C ASTM A53 IPSCO				From (ft.) Surface		To (ft.) 84		9. Static Water Level 45 ft. below ground surface	
Dia. (in.) 4		Screen type, material & slot size S.S. .15 SLOT				From (ft.) 84		To (ft.) 87		10. Pump Test Pumping level 52 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ?	
7. Grout or Other Sealing Material Method MOUNDED AROUND CASING											
Kind of Sealing Material BENSEAL		From (ft.) Surface		To (ft.) 80		# Sacks Cement 3 S		11. Well Is 16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE No											
13. Constructor / Supervisory Driller											
CWM		Lic #		Date Signed 08-18-2016		Drill Rig Operator		Lic or Reg #		Date Signed 08-18-2016	
CWM											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		25

Comment:

Created On: 09-13-2016

Updated On: 12-09-2019

Review Status: