

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				T1274		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MANECKE, MARGEE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W6740 HILLTOP DR								Town of ONALASKA				W6740	
City ONALASKA						State WI		Zip Code 54650				Street Address or Road Name and Number W6740 HILLTOP DR	
County La Crosse		Co. Permit # 26367		Notification # 22141867		Completed 03-24-2006		Subdivision Name HERITAGE HLS				Lot # 2 Block # 5	
Well Constructor (Business Name) LYSAKER WELL DRLG & SERVICE LLC				Lic. # 6968		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.9137 °N -91.2421 °W				Method Code GCD013	
Address N5452 EAGLE CIRCLE LANE ONALASKA WI 54650				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 29 17 N 7 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? WATER SUPPLY					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
4		Surface		147		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes - - Y - SAND & GRAVEL			
										From (ft.) To (ft.) Surface 147			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
4		NEW PLAIN END BLACK STEEL ASTM A53B .237 WALL 10.79 LBS WHEATLAND WELDED				Surface		143		103 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
3.5		STAINLESS STEEL 12 SLOT CONT JOHNSON				143		147		16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?			
				Surface						Filled & Sealed Well(s) as needed? No NONE			
13. Constructor / Supervisory Driller													
EL				Lic #		Date Signed		03-24-2006					
Drill Rig Operator				Lic or Reg #		Date Signed		03-24-2006					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		3
Building Drain - Sanitary		20	Sewer - Building Sanitary		25
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 09-14-2006

Updated On: 04-30-2020

Review Status: